


**GOVERNMENT OF ASSAM**  
**OFFICE OF THE PRINCIPAL :: JORHAT ENGINEERING COLLEGE**  
**J O R H A T : A S S A M**

**N O T I C E**

As desired by the participants Bidders in pre bid discussion, the estimated capacity of the AC System for Newly Constructed Auditorium of Jorhat Engineering College will be within the range of 80-90 tonnes. However, it is Bidders responsibility to achieve to design parameters and effective cooling in full house capacity condition.

  
( Dr. Reeta Sarmah )  
Principal,  
Jorhat Engineering College,  
Jorhat-7